

VERIFICATION OF CONFORMITY

No.: IN-SH-CP-5627-22163

Applicant: **Zhejiang Seeton Building Materials Co., Ltd**

Address: **No.69, Binhe Road, Qingshan Industry, Donglin Town, Wuxing District, Huzhou City, Zhejiang Province, China**

Manufacturer: **Zhejiang Seeton Building Materials Co., Ltd**

Address: **No.69, Binhe Road, Qingshan Industry, Donglin Town, Wuxing District, Huzhou City, Zhejiang Province, China**

It has been verified that

Product(s): **Fiberglass Asphalt Shingle**

Specification: **3-tab, Laminated, Mosaic, Fish Scale, Gothic, Wave**

Material: **Fiberglass, Bitumen, Granule, Sand**

are submitted by the applicant to the testing of the product in accordance with the applicant's requirements

The weight loss and behavior on heating and the pliability of the product are deemed to be in conformity with the requirements of

ASTM D3462/D3462M-19 Table 1. The dimensions, the workmanship, finish and appearance and the minimum net mass and

average net mass are tested according with reference to **ASTM D3462/D3462M-19 section 6/ section 7/ section 8.1.10**

on basis of the test report of **SHIN2206016829CM**

This verification is valid from **31 August 2022** until **30 August 2025** and remains valid as long as the manufacturing

Conditions in the plant and the factory production control itself are not modified significantly.

Issue 1. Verified since **31 August 2022**

Authorised by

scan to see the report



IN-SH-CP-5627-22163



Lisa Liang

Manager

Industries Service - CP Certification

SGS-CSTC Standards Technical Services Co., Ltd. Shanghai Branch

The 8th Building, No. 69, Block 1159, Kangqiao East Road, Pudong Dist., Shanghai, China 201319

t +86 (0)21 6119 6300 f +86 (0)21 6119 1853

email CN.CONSTProdcert@sgs.com website www.sgs.com



Disclaimer: Neither SGS-CSTC, any of it affiliated SGS sister organizations nor the SGS Group can be held responsibly for conformity or non-conformity of the actual product with the contents of the Technical File. Copyright of this verification is owned by SGS-CSTC IND Services and may not be reproduced other than in full.

VERIFICATION OF CONFORMITY

No.: IN-SH-CP-5627-22163

continued

Results of examinations are as following:


Test Items	Test Method	Requirements	Results	Verdict
Dimensions	With Reference to ASTM D3462/D3462M-19 Section 6	-	Length (D1301):998 mm, Width (D1301):334 mm; Length (L1003):1000 mm, Width (L1003):325 mm; Length (J1702):998mm, Width (J1702):322mm; Length (B1401):1002mm, Width (B1401):318mm; Length (Y1202):996mm, Width (Y1202):331mm; Length (S1301):998mm, Width (S1301):342mm	-
Workmanship, Finish, and Appearance	With Reference to ASTM D3462/D3462M-19 Section 7	-	The weather surface was uniform in finish. The mineral granules covered the entire surface and were firmly embedded in the asphalt coating. The finished shingles were free of visible defects.	-
Weight Loss and Behavior on heating	ASTM D3462/D3462M-19 Section 8.1.1 & ASTM D228-21 Section 12	Loss of Volatile Matter (%): ≤ 1.5 Appearance: Sliding of granular surfacing ≤ 2	Loss of Volatile Matter (%):0.18 Appearance: No changes and no sliding of granular surfacing.	Pass
Pliability	ASTM D3462/D3462M-19 Section 8.1.7	90°, no cracking 4 of 5 shall pass	5 of specimens passed the pliability test.	Pass
Minimum Net Mass and Average Net Mass	With Reference to ASTM D3462/D3462M-19 Section 8.1.10 & ASTM D228-21 Section 8	-	Average Value: 5517 g/m ² Minimum Value: 5477 g/m ²	-

Statement:

Unless otherwise stated the results shown in this verification refer only to the sample(s) tested. The manufacturer is obligated to guarantee stability of product performance.

Issue 1. Verified since 31 August 2022

Authorised by



Lisa Liang

Manager

Industries Service - CP Certification